



Hurford Timbers - HM WALK MATTE BRUSHED BOX - Wet Sliptest SN120220-5

12 Feb 2020

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

Date Tested:	12 Feb 2020
Test Report Number:	SN120220-5
Client Name & Address:	Hurford Wholesale - 400 Jacobs Well Road, STAPYLTON QLD 4207
Test Site / Surface Tested :	136mm x 12.5mm - HM WALK MATTE - BRUSHED BOX
Sample Information :	Samples and Test Information Supplied by Client
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Record ambient temperature (°C)	26
Testing Officer :	Shenea Neill
Testing Officer :	#1133 - Munro-Stanley Portable Skid Tester #1133 - 31.10.2019
Testing Officer Signatory:	

Test Results :

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	Surface Picture
SAMPLE 1	45	45	45	45	45	45	
SAMPLE 2	45	45	44	44	44	44	
SAMPLE 3	45	45	44	44	44	44	
SAMPLE 4	45	45	45	45	45	45	
SAMPLE 5	45	45	45	44	44	44	

Mean BPN Slip Resistance Value (SRV)	44
Variation to Standard Mean BPN Slip Resistance Value (SRV)	44
CLASSIFICATION using Slider 96 (4S Slider)	P3 = 35 - 44

Page 1 of 1 - END OF REPORT